

## Government Of West Bengal Office Of The Director General West Bengal Fire & Emergency Services 13D, Mirza Ghalib Street, Kolkata - 16

Memo no.:IND/WB/FES/20192020/56216

Date: 17-08-2022

From:

Divisional Fire Officer
Fire Prevention Wing,
West Bengal Fire & Emergency Services

To: Delhi Public School Joka South Kolkata

Delhi Public School (Joka) South Kolkata, Bakrahat Road, Keyatala Hat, Gazipur, P.O.Kanganberia, P.S.

Bishnupur, Dist - South 24 Parganas.Pin 743503

Sub: Renewal of Fire Safety Certificate in respect of G+II storied School named and styled as "Delhi Public School (Joka)" under group Educational Building at the Premises: Joka, South Kolkata, Bakrahat Road, Gajipur, Kheyatala, PO: Kanganberia, PS: Bishnupur, PIN: 743503.

This is in reference to your application no. 0125191221200074 dated 16-05-2022 regarding the Renewal of Fire Safety Certificate in respect of G+II storied School named and styled as "Delhi Public School (Joka)" under group Educational Building at the Premises: Joka, South Kolkata, Bakrahat Road, Gajipur, Kheyatala, PO: Kanganberia, PS: Bishnupur, PIN: 743503.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

## Recommendation:

- 1. One additional Stand By Fire pump (preferably diesel driven) of required capacity shall have to be installed.
- 2. Fire Pump panel shall have to be replaced with automatic panel which will actuate automatically with fall of pressure.
- 3. Provision of LPG bank shall have to be made at ground level for Chemistry laboratory.
- 4.All vertical duct shall have to be sealed at every floor level both vertically and horizontally with Fire rated material.
- 5.Drive way must be free from any type of obstruction for easy movement of Fire Appliances. No Parking will be allowed on the drive way.
- 6.The Interior finish decoration of the building shall be made with low flame spread material conforming to IS specification.

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the 'Verification of Digitally Signed Document' link and keying in the Unique Number: 0125191221200074.

Page: 1

- 7.To eliminate risk of fire hazards, good housekeeping both for inside and outside of the building shall be maintained.
- 8. Existing electrical wiring of the whole building shall have to be carefully checked for anywhere and tear in them, particularly lines above false ceiling and ducts.
- 9. The notice of fire fighting and evacuation from the building shall be prepared and displayed at all vulnerable of the building.
- 10. The occupants and security staff shall be conversant with installed Fire Fighting equipments of the building and to operate in the event of fire and testing.
- 11. Mock Fire practice and Evacuation Drill shall be performed with all participants at regular interval.
- 12. First Aid fire fighting system shall be provided as per I.S. specification.
- 13.Arrangement shall have to be made for regular checking, testing, and maintenance of all the Fire fighting installation in the building to keep them in perfectly good working condition at all the times.
- 14.If required the old line shall have to be replace with new lines the cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.
- 15.Periodical flashing of water in the Hydrants Pipe line shall be made to maintain the efficiency working performance of the above mention system.
- 16. The Fire Check door shall be sealed with rubber sealing properly in order to prevent the percolation of smoke.
- 17. The Fire safety Audit to be conducted at regular interval and to be recorded in the Fire prevention Maintenance register.
- 18. This Certificate is valid for three (3) years subject to implementation of additional Fire Safety Recommendation as mentioned in Point No.:1,2,3 & 4 within Six (6) months and needs to be regularised accordingly.

Signature valid Digitally signed by KUMAR BAG Date: 2022.08.17

Divisional Fire Officer West Bengal Fire & Emergency Services

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the 'Verification of Digitally Signed Document' link and keying in the Unique Number: 0125191221200074.

Page: 2